



道雄安防科技（上海）有限公司

Doseem Safety Technology (shanghai) Co., Ltd.

空气呼吸器产品合格证

SCBA Product certification



产品型号
Product number
RHZK9CT/B
气瓶编号
Cylinder number
118245430005

产品编号
Product number
2411170002
生产日期
Production Date
2024.11

主要指标

main indicators

1	工作压力 Working pressure		30Mpa
2	减压阀 Pressure reducing valve	供气量 Supply volume	>500L / min
		输出压力 Output pressure	0.8±0.2Mpa
3	中压安全阀开启压力 Medium pressure relief valve opening pressure		1-1.6Mpa
4	警报器报警压力 Alarm alarm pressure		5.5±0.5Mpa
5	呼气阻力 Exhalation resistance		<1000pa

该产品符合 XF124-2013 正压式消防空气呼吸器的要求准予出厂。

The product in line with XF124-2013 "self-provided open-circuit compressed air respirator" requirements to the factory.

检验日期:
Inspection dat
2024.11

检验员(签字)
Inspector (signature)



质量信息反馈卡

Quality information feedback card

尊敬的客户:
Dear Customer

如您在使用中发现质量问题或对产品有好的建议请直接跟工厂质检部联系!

If you use the quality problem in the product, please contact the factory directly with the quality inspection department!

产品型号 Product number	产品编号 Product number	制造年月 Year of manufacture
使用中出现问题或建议		
填表人 Fill in the form	联系方式 Contact information	

道雄安防科技(上海)有限公司
Doseem Safety Technology (Shanghai) Co., Ltd.
电话: 021-67329826
TEL: 021-67329826

地址: 上海市金山区鸿安路599号
Address: 599 Hong'an Road, Jinshan District, Shanghai
网址: www.Doseem.com
http:www.doseem.com